


PRIMARY VOLTAGE						
Protection	Reference	Secondary voltage V	Secondary Current mA	No-load voltage V	Ambient Temperature °C	Rating VA
	44489	2 x 18	2 x 67	2 x 31	T 40 B	2,4
	44490	2 x 24	2 x 50	2 x 42	T 40 B	2,4
	44543	7,5	320	13,1	ta 40/B	2,4
	44677	6	400	10,5	T 40 B	2,4
	44678	9	267	15,5	T 40 B	2,4
	44679	12	200	21	T 40 B	2,4
	44680	15	160	25,3	T 40 B	2,4
	44681	18	133	31	T 40 B	2,4
	44682	24	100	42	T 40 B	2,4
	44683	2 x 6	2 x 200	2 x 10,5	T 40 B	2,4
	44684	2 x 9	2 x 133	2 x 15,5	T 40 B	2,4
	44685	2 x 12	2 x 100	2 x 21	T 40 B	2,4
	44686	2 x 15	2 x 80	2 x 24,5	T 40 B	2,4

* **to be noted** : 2 x 18 V and 2 x 24 V models are non-approved. Those transformers meet all requirement of EN 61558-2-4.

- Insulation voltage 4 KV (6 KV MYRRA test)
- 100 % tested production
- Certification : CCA procedure on request